

Characterization of Gamma Radiation Fields at the University of Wisconsin Nuclear Reactor Lab – 1 MW TRIGA



Michelle Blanchard, Paul Wilson, Chris Staum
University of Wisconsin

Research goals



- ✓ Photon exposure in BP 2 at 1 MW (experimentally). Reason: quantify the gamma induced radiolysis in our supercritical water loop.
- ✓ Normalize MCNP5 model to experimental measurements. Develop flexible tool for determining gamma exposure.
- ✓ Profile radiation levels from photons around UWNR at shutdown

What we actually did



✓ Results

- ✓ Photon exposure in P-Tube (just below BP2) experimentally determined with CaF:MN dosimeters.
 - ✓ 10.1 MR/hr at 1MW
 - ✓ Radiation levels scale linearly above 1 kW. Below 1kW the background is significant.
- ✓ MCNP5 model used to simulate Rads-TLD in P-Tube. Model normalized to experimental results. (Factor of 1.3)
- ✓ Profiled photon exposure (reactor shutdown) with GM detector. 20 minutes to 63 days after shutdown.
- ✓ BP Input File: Replaced core with detailed source. Used to design shielding for Spring 2006 radiography experiments in BP1.

Outline



- ✓ Introduction to facility
- ✓ Shutdown measurements
- ✓ Power measurements with CaF:Mn dosimeter
 - ✓ Results
 - ✓ Accounting for neutrons
- ✓ Benchmark MCNP5 model
 - ✓ Calibration ratio of 1.3
- ✓ Radiography shielding design
 - ✓ Replace Core with Detailed Source
- ✓ Conclusions
- ✓ Acknowledgements

Intro: irradiation facilities

✓ Beam Ports

- ✓ Long cylindrical tube extending from grid box to outside the biological shield

✓ Size


- ✓ 13 Feet Long

- ✓ Inner section: 6 in diameter

- ✓ Outer section: 8 in diameter

✓ Irradiation Time

- ✓ Extended length irradiations



UWNR Beam Ports

Intro: irradiation facilities

- ✓ Pneumatic Tube
 - ✓ Fast response pressurized tube system
 - ✓ Small capsule
 - ✓ Diameter: ~1.25"
 - ✓ Length: ~5.5"
 - ✓ Irradiation time:
 - ✓ Few seconds to several minutes.



"Rabbit"

Shutdown measurements: equipment

- ✓ Thermo Electron Underwater Ion Chamber
 - ✓ (UWDS FHZ 312, SN#: 42540/44)
- ✓ Depth of 65 Feet
- ✓ Exposure rates up to 10,000 R/hr



Underwater Detector w/ Readout Device

Shutdown measurements


✓ Pool locations

✓ 50 Locations

✓ BP, Grid Box, Thermal Column

✓ This figure: 16 hours after reactor shutdown


* Measurements taken 30 min after shutdown to 63 days after shutdown



Shutdown measurements

- ✓ Whale tubes
 - ✓ C2, C8, E8
 - ✓ This figure: 16 hours after reactor shutdown


* Measurements taken 30 min after shutdown to 63 days after shutdown



Shutdown measurements

- ✓ Beam port 3
- ✓ This figure: 6 days (typical) after reactor shutdown
- ✓ Matching pool readings

* Measurements taken 30 min after shutdown to 63 days after shutdown



CaF:Mn TLDs

Exposure measurements with reactor operating

✓ TLD Package

- ✓ Consist of four CaF₂:Mn TLD crystals (0.3 x 0.3 x 0.09 cm, density of 3.1 g/cm³)
- ✓ Housed in Al6061 aluminum alloy casing (0.8x0.8x0.55 cm, density of 2.71 g/cm³)



CaF₂:Mn TLD Package

- ✓ Saturation limit of 500,000 R. Ideal conditions of < 10,000 R
 - ✓ Forced use of P Tube
 - ✓ Dictated exposure times (4-240 seconds) and power levels (1.5kW - 100kW)

CaF:Mn TLDs Results

Sample #	Power (kW)	Time (s)	Dose (kR)	kR/hr
1	1.5	180	1.80	36.0
2	1.5	210	2.08	35.7
3	1.5	240	2.25	33.8
4	4	60	1.09	65.4
5	4	75	1.34	64.3
6	4	90	1.66	66.4
7	10	25	1.00	144
8	10	32	1.23	138
9	10	40	1.57	141
10	30	8	0.91	410
11	30	10	1.19	428
12	30	12	1.47	441
13	100	4	1.55	1395
14	100	6	2.14	1284
15	100	8	3.05	1372

CaF:Mn TLDs

Neutron response



- ✓ Neutron Contribution (Ni foil as neutron monitor)
 - ✓ Effective Neutron Kerma
 - ✓ Secondary gammas
 - ✓ Activation of the TLD
 - ✓ Activation of the Al casing
 - ✓ Charged particles produced in the Al casing

CaF:Mn TLDs

Neutron Response


Power (kW)	Combined Dose Rate (R/hr)	Neutron Only Dose Rate (R/hr)	Gamma Only Dose Rate (R/hr)
1.5	3.51E+04	4.90E3	3.02E+04
4	6.53E+04	1.25E4	5.28E+04
10	1.41E+05	3.29E4	1.09E+05
30	4.26E+05	1.06E5	3.21E+05
100	1.35E+06	3.29E5	1.02E+06

UWNR Dose Rates at Varying Power Levels

✓ TLD Full Power (1 MW) Prediction:

10.1 MR/h

CaF:Mn TLDs Results



Gamma only, Combined, and MCNP Predicted Dose Rates of TLDs

CaF:Mn TLDs

Results

Results show a linear relationship ($R^2=0.9999$) between gamma radiation and the power level within the reactor. This linear fit to the dose rate results gives:

$$\dot{D} \left[\frac{kR}{h} \right] = 10.08 \left[\frac{kR}{h} \right] \cdot P [kW] + 13.2 \left[\frac{kR}{h} \right]$$

where \dot{D} is the dose rate in kR/h and P is the reactor power level in kW . This suggests a shutdown dose rate, due to fission product decay, of 13.2 kR/h , and a full power (1 MW) dose rate of 10.1 MR/h .

UWNR Dose Rates at Varying Power Levels

✓ TLD Full Power (1 MW) Prediction:

10.1 MR/h

Benchmark MCNP5 simulation

- ✓ TLD was created in MCNP5
UWNR Model
 - ✓ Identical geometry, materials, placement
 - ✓ Hot temperature cross sections

Tally	Dose [Rad(TLD)/hr]	Error (%)
CaF ₂ :Mn TLD	7.76E+06	3.30

Benchmark MCNP5 Simulation Calibration Ratio

- ✓ TLD Full Power Prediction: 10.1 MR/h
- ✓ MCNP5 Full Power Prediction: 7.76 MR/h
- ✓ Offset Ratio (TLD/MCNP5): 1.301


Beam Port Input File

Reason

- ✓ MCNP5 UWNR Model
 - ✓ Simulates core w/ emphasis on criticality
 - ✓ Good for determining dose rates very close to the core
 - ✓ Bad for determining dose rates far from the core
 - ✓ Dose Rate (<3% Error) outside of Biological Shield takes many years

Beam Port Input File Geometry

- ✓ UWNR Model w/out Core




Beam Port Input File

Source


- ✓ Source needed to mimic core
 - ✓ Simple Source
 - ✓ Quick and efficient first order approximation
 - ✓ Average fission information
 - ✓ Detailed Source
 - ✓ In-depth precise analysis
 - ✓ UWNR specific photon information

Beam Port Input File Validation of Results


Full Core



Simple Source



Detailed Source



Beam Port Input File

Calibration Ratio

- ✓ Simple Source
 - ✓ Not Valid: Incorrect Photon Behavior
- ✓ Detailed Source partially valid
 - ✓ Correct photon behavior
 - ✓ Nearly accurate dose rate magnitude
 - ✓ Normalized to MCNP5 model / CaF dosimeters

Conclusions



- ✓ Accurately mapped shutdown radiation with GM detector (good agreement with CaF dosimeter)
 - ✓ 20mins – 63 days after last reactor operation
- ✓ Determined dose rates in P Tube for operating conditions
 - ✓ Dose Rates (1.5 kW – 100kW): 30.2 kR/hr to 1020 kR/hr
 - ✓ Predicted Dose Rates (1 MW): 10.1 MR/hr
- ✓ Normalized MCNP5 model to experimental results for gamma exposure in P-Tube.
 - ✓ Calibration Factor of 1.3
- ✓ Developed computational model of photon radiation external to the beam ports at full power. Used to design shielding for Spring 2006 radiography experiment.
 - ✓ Corrects for replacing core with a disk source: MCNP5 to disk source conversion
 - ✓ Normalizes MCNP5 to experimentally measured dose rates (CaF)
 - ✓ 3-4 day computer time for <5% results (compared to several years with MCNP5 model)

Acknowledgement



- ✓ Sandia National Laboratory Radiation Metrology Lab (specifically David Chichester, David W Vehar, and Patrick J Griffin)
- ✓ Funding from contract Dept of Energy. INIE via Penn State, contract # 2401-UW-DOE-4423 (PSU/INIE).